

U.S. EPA MARKAL:
Representing SO_x and NO_x control
technologies in MARKAL using an
engineering-cost model.

Joe DeCarolis and Samudra Vijay
Integrated Systems Analysis Workgroup
Air Pollution Prevention and Control Division
U.S. EPA

30 June 2006

ISA Workgroup's Role in the EPA

- Support ORD Global Change Program (MARKAL modeling)
 - Develop and assess scenarios of future technologies over 50 year time horizon
 - Focus on transportation and electricity sector
 - Improve understanding of how technological change can impact future air pollutant and greenhouse gas emissions
- Perform energy technology assessments with a focus on environmental impacts
- Provide useful analyses and tools to states and regions that are trying to make energy decisions



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions


2

Motivation

- U.S. electric sector emissions of SO_x and NO_x are constrained by both the Clean Air Act and CAIR (Clean Air Interstate Rule)
- Coal is responsible for most of the electric sector emissions
- Several retrofits to existing coal plants can be made to significantly reduce SO_x and NO_x emissions
- **Critical to include these retrofits in MARKAL; otherwise existing coal capacity is replaced too quickly with cleaner technology in order to meet emissions constraints**




Profile of U.S. NO_x Emissions



Source: EPA, 2005 (National Emission Trends)



Profile of U.S. SO_x Emissions



Source: EPA, 2005 (National Emission Trends)



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

5

Coal in EPA U.S. National MARKAL Database

General coal representation

- Both surface and underground mine types
- Coal supply curves specified by region: Dakotas, Gulf, Interior, Northwest, Powder River, Rocky Mountains, Southwest

Coal characteristics affecting emissions

- 3 coal types: bituminous, sub-bituminous, and lignite
- 3 sulfur levels:
 - High (≥ 1.68 lbs SO_x / MBTU)
 - Medium (>0.6 and <1.68 lbs SO_x / MBTU)
 - Low (≤ 0.6 lbs SO_x / MBTU)




RESEARCH & DEVELOPMENT





Building a scientific foundation for sound environmental decisions

6

SO_x Control: FGD (Wet Scrubbers)



- Most widely-used process is limestone forced oxidation (LSFO)



- LSFO operating parameters: reagent ratio = 1.05-1.1, L/G = 70-120, auxiliary power = 1.2-2%
- State-of-the-art is 95% SO₂ removal
- Capital intensive, space requirements
- Over 200 GW of wet scrubbers installed on coal-fired boilers worldwide (~30%)



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

7

NO_x Control Technologies (Commercially Established)

- Primary – reduce the NO_x produced in the primary combustion zone
 - Low NO_x burners (LNBS)
 - Overfire air (OFA)
- Secondary - reduce the NO_x already present in the flue gas
 - Reburning
 - Selective non-catalytic reduction (SNCR)
 - Selective catalytic reduction (SCR)




RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

8

Low NO_x Burners (LNB)

- Limit NO_x formation by delaying complete mixing of fuel and air
 - Reduced oxygen in primary flame zone
 - Reduced flame temperature
 - Reduced residence time at peak temperature
- Can provide reductions in excess of 50% from uncontrolled level




RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

9

Selective Non-Catalytic Reduction (SNCR)



- Urea or NH₃ injection, generally between 980 to 1150 °C
- 30 to 60% NO_x reduction
- Low capital costs
- Load following, NH₃ slip, performance on larger boilers
- Applications: cyclone, wall, tangential boilers 50-620 MW

Source: Srivastava et al. (2005)



RESEARCH & DEVELOPMENT


Building a scientific foundation for sound environmental decisions

16

10

Selective Catalytic Reduction (SCR)

- $2\text{NH}_3 + 2\text{NO} + 1/2 \text{O}_2 \rightarrow 2\text{N}_2 + 3\text{H}_2\text{O}$
- $4\text{NH}_3 + 2\text{NO}_2 + \text{O}_2 \rightarrow 3\text{N}_2 + 6\text{H}_2\text{O}$
- Configuration alternatives
 - "High-dust" SCR-APH-PM-FGD – most used
 - "Low-dust" PM-SCR-APH-FGD
 - "Tail-end" APH-PM-FGD-SCR
- NH_3 injection, generally between 350-400 °C
- More than 90 percent reduction is possible
- Capital intensive, space requirements
- Over 120 GW of SCR systems installed on coal-fired boilers worldwide (~20%)



Source: Srivastava et al. (2005)



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

11

Data Sources

- **DOE EIA 767** – Plant technical data, no fuel characteristics
- **DOE EIA 860** – Plant specific fuel characteristics and consumption data
- **EPA CAMD** – Emissions data
- Plant characteristics, fuel type, plant factor, S content, ash content, heat content, bottom type, firing type, etc.



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

12

Tools

- CUECost (EPA/ORD model)
 - Engineering-economic cost model
 - NO_x retrofit cost for each plant in population
- Script in VBA to automate calculations
 - Cost estimation based on most important parameters (i.e., boiler size, coal type, ash content, PLF, heat rate)
 - Individual plant and fuel characteristics taken into account (i.e., firing type, bottom type, S content, ash content)



Method (Part 1)

- VBA script ran CUECost for all U.S. coal boilers listed in EPA's Clean Air Markets database.
- Result is a spreadsheet containing the following estimates for each boiler:
 - Input sulfur level (lbs/MBTU)
 - Boiler capacity (MBTU/yr)
 - Heat Input (MBTU/hr)
 - Retrofit costs: capital, O&M
 - SO_x and NO_x emissions (short tons / yr) assuming a given retrofit.
- The following retrofits were considered : FGD, LNB, SCR, SNCR, LNB-SCR, LNB-SNCR.



Method (Part 2)

Estimating SO_x control parameters


- Spreadsheet sorted by coal type and sulfur level to determine level of existing capacity with and without FGD.
- Calculate weighted average FGD retrofit costs and emissions assuming no pre-existing SO_x control (by sulfur level and coal type).

Estimating NO_x control parameters


- Spreadsheet sorted by coal type to determine level of existing capacity with and without various NO_x control retrofits.
- For each boiler, estimate cost and emissions for applicable NO_x control retrofits.
- Calculate weighted average NO_x retrofit costs and emissions by coal type.
 - Boilers with SCR or SNCR are assumed to be fully retrofitted.



MARKAL RES for Coal Retrofits



MARKAL Results with Old Retrofits



- “New Coal” includes new pulverized coal with advanced SO_x/NO_x controls (FGD+LNB+SCR) and IGCC.
- “Combustion Turbines” include simple- and combined-cycle gas turbines as well as distillate oil turbines.




RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

17

MARKAL Results with New Retrofits




- “New Coal” includes new pulverized coal with advanced SO_x/NO_x controls (FGD+LNB+SCR) and IGCC.
- “Combustion Turbines” include simple- and combined-cycle gas turbines as well as distillate oil turbines.



RESEARCH & DEVELOPMENT

Building a scientific foundation for sound environmental decisions

18



19

Summary

- Boiler-level engineering-economic model (CUECost) used to estimate average emissions and retrofit costs associated with SO_x and NO_x control.
- SO_x and NO_x retrofits added to U.S. EPA MARKAL, including all appropriate combinations of primary and secondary controls.
- With Clean Air Act and CAIR constraints, accurate results from the U.S. EPA MARKAL electric sector depend on accurate representation of SO_x/NO_x control retrofits for coal.

20