



ALMA MATER STUDIORUM
UNIVERSITÀ DI BOLOGNA



Data centres in Ireland

SCENARIO ANALYSIS FOR ETSAP WORKSHOP

Leonardo Collina, MSc student
Università di Bologna / University College Cork

Data centres overview

Physical facilities that companies use to host their critical applications and data.
Demand increased rapidly in recent years and will further increase stimulated by new data-intensive technologies such as artificial intelligence, machine learning.


Why is it relevant for the energy system?

Electricity consumption for:

- IT equipment (servers, storage, transmission)
- Cooling system
- Others

Hyperscale DCs can have a demand capacity >100 MW

But... waste heat recovery is possible!



Why is it relevant for Ireland?

Factors that make it perfect for hosting DCs:

- Weather conditions
- Good fibre connections with US
- Attractive corporation tax


Factors that make DCs hard to handle:

- Big growth expected in the next decade
- Concentration in Dublin area
- Isolated energy system (lack of grid connections with other countries)
- Decarbonization targets

Ireland decarbonization pathways

“Climate Action & Low Carbon Development (Amendment) Act 2021” targets to reduce greenhouse-gases [GHGs] by:

- 51% by 2030,
- net-zero by 2050.



A33E61:

- 33% reductions from agriculture,
- 61% reductions from energy & industry by 2030


More mitigation scenarios developed by the MaREI Energy Policy and Modelling Group available:



<https://tim-carbon-budgets-2021.netlify.app/scenarios>

<https://zenodo.org/record/5517363#.YZ-uVtDP02w>

DCs in TIM





40 time-slices

Season	Weekly	DayNite
Wi	NW	A (0-7)
Sp	WD	B (7-9)
Su		C (9-17)
Au		D (17-19)
		E (19-0)

DCs in TIM


Cooling system electricity and waste heat are expressed as share of the total consumption of the process.

Shares are taken from a thermodynamic model on hourly level, then aggregated on time-slices level in TIM.



Demand projections

1_Flat: Flat demand



Capacity: 1100 MW (already connected)


Eirgrid, All-Island-Generation-Capacity-Statement-2020-2029

Load factor: 40%

Eirgrid, All-Island-Generation-Capacity-Statement-2020-2029

Demand projections

2_LF: load factor increase




Capacity: 1100 MVA
(already connected)

Load factor: grows linearly
from 40% up to 70% in 2030

Eirgrid expects the load factor to rise as customers build out to their full potential.

Demand projections

3_cap: All current applications approved



Capacity:


- 1800 MVA in 2022
(connection agreements already in place)
- +2000 MVA up to 2030
(additional requests already received)

CRU21060-CRU-consultation-on-Data-Centre-measures

Load factor: 40%

Demand projections

4_LFcap: All current applications approved and load factor increase



Capacity:

- 1800 MVA in 2022
(connection agreements already in place)
- +2000 MVA up to 2030
(additional requests already received)

CRU21060-CRU-consultation-on-Data-Centre-measures


Load factor: grows linearly from 40% up to 70% in 2030

DCs elc vs total elc demand


	Capacity [MVA]			Load factor [%]		Demand [PJ]	
	2021	2022	2030	2021	2030	2021	2030
E61-1_Flat	1100	1100	1100	40	40	14.19	14.19
E61-2_LF	1100	1100	1100	40	70	14.19	24.83
E61-3_Cap	1100	1800	3800	40	40	14.19	47.93
E61-4_LFCap	1100	1800	3800	40	70	14.19	83.89

Scenarios recap


DCs electricity vs total electricity



DCs electricity as share of total electricity




New capacity installed




- Investments in gas power plants in 2024 due to **coal phase out** in 2025
- Each year a considerable level of new wind off-shore capacity
- Some investment in CCS technologies in 2030

New capacity installed (Up to 2030)

Total new capacity up to 2030




Demand projections comparison




- In the next 8 years the system will need from **16 to 17.8 GW of new capacity** to meet decarbonization targets
- This 1.8 GW difference is covered mostly from **wind off-shore**
- But... in the case of very high demand the further difference is covered by **new gas power plants**

Waste heat recovery

Heat recovery potential




Heat to DH Network




From 2027, in 3° and 4° demand scenarios, **new investments** in DH networks are **no longer cost optimal**. While the potential grows the share of heat actually used decrease.

What if no heat recovery?

Heat usage by sector (2022-2030)



Service fuel demand for SC, SH, WH (2022-2030):
Difference between heat recovery/no heat recovery




- The heat recovered from DCs is used for **space and water heating** in service and residential sectors.
- Heat is **replaced** mostly by **gas** and to a small extent by **oil**. In the 4th case there's also a big contribution of **biomass**.
- The amount of **gas avoided** by recovering the waste heat is **lower** than the amount of **additional gas required** in the power sector due to DCs growth (18.09 PJ vs 53.90 PJ in the 4th case)

Emissions by sector

Emissions from the **power sector** increase as the demand from DCs grows



more pressure on the other sectors to speed up the transition



- What happens in 2029 to the industrial sector?
- What happens in 2030 to the residential sector?

New investments in greener technologies?


CO2 Price

CO2_price = 2 kEur/ton ←


No cheaper options to mitigate emissions than **Direct Air Capture**

«backstop» technology used to make the scenario feasible

CO2 price



Backstop emissions



Discussions

Assumptions / input data:

- Cooling system
- Waste heat
- Load factor increase



Lack of reliable data:
Literature review and
sensitivity analysis

Analysis:

- Impact to other sectors
- Comparison with less challenging scenarios



New ideas are welcome

THANK YOU FOR LISTENING

leonardo.collina4@studio.unibo.it

